

PANEL SCREWS W/ WASHERS
@ 12" O.C. W/ MINIMUM 1/4"
PENETRATION INTO
STRUCTURAL SUPPORT
(U.N.O.)

EXTREME ROOF PANEL

VALLEY FLASHING

1/8" SIP TAPE ON
(WINTER) WARM
SIDE OF PANEL

CONTINUOUS 1/2" PANEL
SEALANT OR FILL GAPS
WITH 2-PART
EXPANDABLE FOAM AT
FOAM JOINT

STRUCTURAL SUPPORT
MINIMUM 3" WIDE FOR
MINIMUM 1 1/2" BEARING
FOR PANEL ON EACH SIDE

SECTION
NOT TO SCALE

DETAIL TITLE : ROOF VALLEY (FLUSH FOAM)

DETAIL NO. : EP-408

PAGE NO. : 4 - 8

UPDATED : MARCH 2017

Extreme Panel

TECHNOLOGIES, INC.

STRUCTURAL INSULATED PANELS