

CONTINUOUS $\frac{3}{8}$ " # $\frac{1}{2}$ "
PANEL SEALANT TYPICAL
EACH SIDE

2x SUBFASCIA

1 $\frac{1}{2}$ " SCREWS @ 8" O.C.
OR 2"-8d NAILS @ 6"
O.C. TOP AND BOTTOM
OF PANEL (U.N.O.)

1x FASCIA
BOARD BY
OTHERS

3" CONST. LAGS @ 24"
O.C. OR 16d NAILS @ 16"
O.C. TO ATTACH FASCIA
TO SUBFASCIA (U.N.O.)

BEVELED BLOCK ATTACHED TO
SUBFASCIA W/ 3" CONST. LAGS @ 24"
O.C. OR 16d NAILS @ 12" O.C.
BEFORE SUBFASCIA IS INSTALLED IN
ROOF PANEL - FINISH UNDERSIDE W/
 $\frac{7}{16}$ " OSB (U.N.O.)

NOTE: CONSULT LOAD DESIGN
CHARTS FOR MAXIMUM OVERHANG

SECTION
NOT TO SCALE

DETAIL TITLE : FULL PANEL OVERHANG (OPTIONAL)

DETAIL NO. : EP-416

PAGE NO. : 4 - 16

UPDATED : MARCH 2017

Extreme Panel

TECHNOLOGIES, INC.

STRUCTURAL INSULATED PANELS

